



PANEL No.	No.	CREDIT	KW	IN. KVA	NAME of MACHINE	WRNG SIZE	REMARKS
<b>L - 21 X3.1 - 2nd Floor</b>							
<b>CABLE No. 32P - 202 600V NYY 4C - 2</b>							
1	①	ELCB - 2P 50/20	1e2W 230V 2380 VA		Lighting fittings R - 401 x 38	NYY	
2	②	ELCB - 2P 50/20	1e2W 230V 1880 VA		Lighting fittings R - 401 x 28	NYY	
3	③	ELCB - 2P 50/20	1e2W 230V 950 VA		Lighting fittings R - 401 x 16	NYY	
4	④	ELCB - 2P 50/20	1e2W 230V 1800 VA		Lighting fittings R - 401 x 30	NYY	
5	⑤	ELCB - 2P 50/20	1e2W 230V 1400 VA		Lighting fittings R - 401 x 19	NYY	
6	⑥	ELCB - 2P 50/20	1e2W 230V 2340 VA		Lighting fittings R - 401 x 39	NYY	
7	⑦	ELCB - 2P 50/20	1e2W 230V 2880 VA		Lighting fittings R - 401 x 48	NYY	
8	⑧	ELCB - 2P 50/20	1e2W 230V 1400 VA		Lighting fittings R - 401 x 41	NYY	
9	⑨	ELCB - 2P 50/20	1e2W 230V 1400 VA		Spare		
10	⑩	ELCB - 2P 50/20	1e2W 230V 1600 VA		Lighting fittings Spare		
11	⑪	ELCB - 2P 50/20	1e2W 230V 1400 VA		Lighting fittings Spare		
12	⑫	ELCB - 2P 50/20	1e2W 230V 1400 VA		Lighting fittings Spare		
13	⑬	ELCB - 2P 50/20	1e2W 230V 1400 VA		Transformer 1e2W 400V/100V 1 KVA		
14	⑭	MCCB - 2P 50/20	1e2W 100V 100 VA		Emergency lighting fittings e - 301 x 38	NYY	
15	⑮	MCCB - 2P 50/20	1e2W 100V 160 VA		Guiding lighting fittings X - 201 x 4	NYY	
16		E NYY 1 - 1C		Total	34.8W 400V 21.7 KVA		
<b>L - 22 X19.1 - 2nd Floor</b>							
<b>CABLE No. 32P - 202 600V NYY 4C - 2</b>							
1	①	ELCB - 2P 50/20	1e2W 230V 2100 VA		Lighting fittings R - 401 x 32, V - 401 x 3	NYY	
2	②	ELCB - 2P 50/20	1e2W 230V 1800 VA		Lighting fittings R - 401 x 30	NYY	
3	③	ELCB - 2P 50/20	1e2W 230V 1400 VA		Lighting fittings R - 401 x 30	NYY	
4	④	ELCB - 2P 50/20	1e2W 230V 1800 VA		Lighting fittings R - 401 x 30	NYY	
5	⑤	ELCB - 2P 50/20	1e2W 230V 1400 VA		Lighting fittings R - 401 x 24	NYY	
6	⑥	ELCB - 2P 50/20	1e2W 230V 1440 VA		Lighting fittings R - 401 x 24	NYY	
7	⑦	ELCB - 2P 50/20	1e2W 230V 1920 VA		Lighting fittings R - 401 x 32	NYY	
8	⑧	ELCB - 2P 50/20	1e2W 230V 1920 VA		Lighting fittings R - 401 x 32	NYY	
9	⑨	ELCB - 2P 50/20	1e2W 230V 1920 VA		Lighting fittings R - 401 x 32	NYY	
10	⑩	ELCB - 2P 50/20	1e2W 230V 2040 VA		Lighting fittings R - 401 x 34	NYY	
11	⑪	ELCB - 2P 50/20	1e2W 230V 1400 VA		Lighting fittings R - 401 x 45	NYY	
12	⑫	ELCB - 2P 50/20	1e2W 230V 600 VA		Lighting fittings R - 401 x 10	NYY	
13	⑬	ELCB - 2P 50/20	1e2W 230V 1400 VA		Spare		
14	⑭	ELCB - 2P 50/20	1e2W 230V 1400 VA		Spare		
15	⑮	ELCB - 2P 50/20	1e2W 230V 1400 VA		Spare		
16	⑯	ELCB - 2P 50/20	1e2W 230V 1400 VA		Spare		
17	⑰	E NYY 1 - 1C		Total	34.8W 400V 21.5 KVA		

TITLE THAT ALLIANCE TEXTILE CO., LTD.

Lighting Wiring of New Mill  
(Phase - / 2nd Floor)DRAWN *K. Sekai* DATE 25/DEC./1995 SCALE 1/300CHECKED *U. Ayamach* DWG No.APPROVED *[Signature]* TX - E - 014

TO TOBO TOYOB ENGINEERING CO LTD