


PANNEL No.	No.	Circuit Breaker	KW/	In. At.	Name of MACHINE	WRNG SIZE	REMARKS
<b>L - 13</b> X6.m - 1st Floor							
CABLE No. 41P - 108 600V NYY 4C - 2							
2F TR PL	①	ELCB - 2P 50/20	1φ 2W 230V 2880 VA		Lighting lamps R - 401 × 48	NYY 2 - 3C	
	②	ELCB - 2P 50/20	1φ 2W 230V 2880 VA		Lighting lamps R - 401 × 48	NYY 2 - 3C	
	③	ELCB - 2P 50/20	1φ 2W 230V 3240 VA		Lighting lamps R - 401 × 39	NY 2 - 3C	
	④	ELCB - 2P 50/20	1φ 2W 230V 3240 VA		Lighting lamps Spare	NY 2 - 3C	
	⑤	ELCB - 2P 50/20	1φ 2W 230V 3240 VA		Lighting lamps Spare	NY 2 - 3C	
	⑥	ELCB - 2P 50/20	1φ 2W 230V 3240 VA		Lighting lamps Spare	NY 2 - 3C	
E NYY 1 - 1C					Total: 3φ 4W 400V 81 KVA		
<b>L - 14</b> X13.p - 1st Floor							
CABLE No. 41P - 108 600V NYY 4C - 2							
2F TR PL	①	ELCB - 2P 50/20	1φ 2W 230V 3090 VA		Lighting lamps R - 401 × 51	NY 2 - 3C	
	②	ELCB - 2P 50/20	1φ 2W 230V 3090 VA		Lighting lamps R - 401 × 51	NY 2 - 3C	
	③	ELCB - 2P 50/20	1φ 2W 230V 3090 VA		Lighting lamps R - 401 × 51	NY 2 - 3C	
	④	ELCB - 2P 50/20	1φ 2W 230V 3210 VA		Lighting lamps R - 401 × 42	NY 2 - 3C	
	⑤	ELCB - 2P 50/20	1φ 2W 230V 438 VA		Lighting lamps R - 401 × 8	NY 2 - 3C	
	⑥	ELCB - 2P 50/20	1φ 2W 230V 1920 VA		Lighting lamps R - 401 × 32	NY 2 - 3C	
	⑦	ELCB - 2P 50/20	1φ 2W 230V 438 VA		Lighting lamps V - 402e × 4	NY 2 - 3C	
	⑧	ELCB - 2P 50/20	1φ 2W 230V 3210 VA		Lighting lamps Spare	NY 2 - 3C	
E NYY 1 - 1C					Total: 3φ 4W 400V 19.5 KVA		
<b>L - 11</b> X2.i - 1st Floor							
CABLE No. 32P - 109 600V NYY 4C - 2							
2F TR PL		ELCB - 2P 50/20			TRANSFORMER 1φ 2W 400V / 100V 1 KVA		
	91	MCCB - 2P 50/20	1φ 2W 100V 390 VA		Emergency lighting lamps e - 301 × 39 + 21	NY 2 - 3C	
	92	MCCB - 2P 50/20	1φ 2W 100V 510 VA		Guiding lighting lamps X - 201 × 8 + 5	NY 2 - 3C	
E NYY 1 - 1C					Total: 3φ 4W 400V 23.0 KVA		
<b>L - 12</b> X15.i - 1st Floor							
CABLE No. 32P - 109 600V NYY 4C - 2							
2F TR PL	①	ELCB - 2P 50/20	1φ 2W 230V 1080 VA		Lighting lamps PHASE -	NY 2 - 3C	
	9	ELCB - 2P 50/20	1φ 2W 230V 540 VA		Lighting lamps PHASE -	NY 2 - 3C	
	10	ELCB - 2P 50/20	1φ 2W 230V 3220 VA		Lighting lamps R - 401 × 37	NY 2 - 3C	
	11	ELCB - 2P 50/20	1φ 2W 230V 1200 VA		Lighting lamps R - 401 × 20	NY 2 - 3C	
	12	ELCB - 2P 50/20	1φ 2W 230V 3210 VA		Lighting lamps Spare	NY 2 - 3C	
E NYY 1 - 1C					Total: 3φ 4W 400V 23.0 KVA		

## 3 LUMINAIRE DRAWING

THAI ALLIANCE TEXTILE CO., LTD.  
Lighting Wiring of New Mill  
(Phase - / 1st Floor)

DRAWN *K. Sekar* DATE 25/DEC./1995 SCALE 1/300  
 CHECKED *V. Jayamani* DWG No. TX - E - 015  
 APPROVED *K. Sekar*

TOBO TOYOBO ENGINEERING CO LTD